

West Bengal Tourism Development Corporation Limited
(A Government of West Bengal undertaking)
Office of the General Manager (North)
Mainak Tourism Property Complex, Mallaguri, Siliguri

Memo No. 128/XI(38)/GM(N)/WBTDCL-2020-21 Date: 08/02/21

NOTICE INVITING QUOTATION No: 11/SE (N)/WBTDCL/2020-2021

Name of work: **“Supply, Installation, Testing & Commissioning of Electrical fan work at Hill Top Tourism Property in the dist. Of Kalimpong.”**

Sealed quotations are invited from experienced bonafide bidders for the subject work by the Undersigned. Interested bidders are requested to submit a formal application to obtain permission to participate in the quotation along with following documents:


- i) IT, GST & PT Clearance Certificate
- ii) Trade license
- iii) Credentials of similar jobs

Acceptance of quotation will rest with the SE(North), WBTDCL who does not bind himself to accept the lowest or any other or part thereof. No reason will be furnished for acceptance or rejection of any one or all the tenders.

Date & Time Schedule:

Sl. No	Particulars	Date & Time
1	Date and time of Publishing NIQ	09.02.2021 ; 11.00AM
2	Starting Date of Application for Receiving Quotation Paper.	09.02.2021 ; 11.00AM
3	Closing Date & Time of Submit Quotation Paper.	19.02.2021 ; 03.00PM
4	Quotation opening date for Technical Proposal.	19.02.2021 ; 04.00PM
5	Quotation opening date for Financial Proposal.	To be notified later

Yours faithfully


Superintending Engineer (North)
WBTDCL

Memo No: 128/XI(38)/GM(N)/WBTDCL-2020-21 **Date:** 08/02/21

Copy forwarded to: THE

1. Managing Director, WBTDCL
2. General Manager (North), WBTDCL
3. Notice Board, Hill Top Tourism Property, WBTDCL
4. Office Notice Board
5. Ratan Debnath, DBA, Tourism Centre WBTDCL, Kolkata with request to Uploading in WBTDCL Website.


Superintending Engineer (North)
WBTDCL

Issued to:-

ANNEXURE-I

TECHNICAL BID

To,
Superintending Engineer (North)
West Bengal Tourism Development Corporation Limited
Mainak Tourism Property
Hill Cart Road, Pradhan Nagar,
Siliguri.

Sub-“Supply, Installation, Testing & Commissioning of Electrical fan work at Hill Top Tourism Property in the dist. Of Kalimpong.”.

Sir,

With reference to your NIQ No: **11/SE (N)/WBTDCL/2020-2021** Date: _____
I am/we are furnishing herewith details of Technical bid as under:-

1. Name of the agency :
2. Address :
3. Name of the contact person :
4. Contact Number :

<u>Sl No</u>	<u>Description of items</u>	<u>Details</u>
1	PAN No	
2	GSTIN	
3	P.Tax	
4	Trade License	
5	I T Return for FY -2019-20 (Sarl)	
6	Credential	

DECLARATION: - I/we hereby declare that details furnished above true and correct. I/we have read over the entire terms and condition of the quotation document and abide by the same.

(Signature and name of the quotationer/bidder with stamp)

ANNEXURE-II**FINANCIAL BID**

To,
 Superintending Engineer (North)
 West Bengal Tourism Development Corporation Limited
 Mainak Tourism Property
 Hill Cart Road, Pradhan Nagar,
 Siliguri.

Sub— “ Supply, Installation, Testing & Commissioning of Electrical fan work at Hill Top Tourism Property in the dist. Of Kalimpong. ”.

Sir,

With reference to your NIQ No: **11/SE (N)/WBTDCL/2020-2021**
 we are putting in our offer financial bid as under:-

Date:

Sl. No.	Description of Item	Qty	Unit	Rate	Amount
1	Supply Havells 400 mm Swing wall fan Or Equivalent Brand approve by EIC	2	Nos		
2	Supply Havells Fusion 1200 mm CF Pearl White Silver / Pearl Ivory Gold / Silver Blue / Espresso Brown / Beige Brown Or Equivalent Brand approve by EIC	14	Nos		
3	Fixing only ceiling fan complete with blades, canopy, fork, rubber bush etc. incl. S&F connecting wire for down rod upto 30 cm incl. painting the rod with approved paint and making necessary connection as required by 2x1.5 sqmm flexible copper wire.	16	Each		
4	Supply & Fixing 240 V 6 A Modular type switch (Brand approved by EIC) on existing GI Modular type switch board having top cover plate and making necessary connections as required	15	Each		
5	Supply & Fixing 240 V, 6A, 5 pin Modular type plug socket (Brand approved by EIC), without switch & plug top, on existing GI Modular type switch board with top cover plate and making necy. connections with PVC Cu wire and earth continuity wire etc.	10	Each		
6	Supplying & Fixing GI Modular Switch Board of the following sizes complete with three no. suitable size Copper bar with holes (for Ph, N & E) fixed on bakelite/Hard Rubber insulator over the MS welded chairs incl. top cover flushed in wall for housing the board after cutting the brick wall incl. making earthing attachment, painting and mending good damages to building works				
	(a) 4 Module	4	Set		
	(b) 6 Module	6	Set		

7	Distribution wiring in 1.1 KV grade 2x22/0.3 (1.5 sqmm) single core stranded 'FR' PVC insulated & unsheathed copper wire (Brand approved by EIC) partly in 20mm size PVC rigid conduit 'FR' (Precision make) [for ceiling portion only] and in 19mm bore, 3mm thick polythene pipe [for horizontal & vertical run embedded in wall], with 1x22/0.3 (1.5 sqmm) single core stranded 'FR' PVC insulated & unsheathed copper wire for ECC, to light/fan/call bell points with Modular type switch (Brand approved by EIC) fixed on Modular GI switch board complete with 2 no. suitable size "Ph & N" copper bar with top cover plate making earthing attachment fixed on wall incl. mending good damages to original finish. [only PVC Rigid Conduit on ceiling and remaining portion concealed]				
	(a) Average run 6 mtr	12	Point		
	(b) Average run 8 mtr	10	Point		
8	Supplying and Drawing 1.1 KV single core stranded 'FR' PVC insulated & unsheathed single core stranded copper wire (Brand approved by EIC) of the following sizes in the prelaid polythene pipe and by the prelaid GI fish wire and making necy. connection as required				
	(a) 2 x 22/0.3 (1.5 sqmm)	90	MTR		
TOTAL					

I / We agree to carry out the above mentioned work
 (_____ Rupees _____) of the project including all taxes and
 charges.

Date -

Place-

 (Signature and name of the quotationer/bidder with stamp)